

Last Updated 1/24/23		STARK CO										Stark County Lift Stations																		
Lift Station		Location		Pump Rate	Design Discription						Motor Description				In Operation	Force Main Description			Discharges To	Power	Generator	Rail								
No.	Name	Township	Street Address	GPM	Mfg. *	Model No.	Cap.	No. & Type	Imp.Dia.	TDH	HP	Phase	Voltage	RPM	Station/Pumps	Size	Length	Type		Company	Required	System								
X	1	Lake Cable #1	Jackson	5426 Peninsula Dr,NW		MYR	4RX50M4-21	150	2-Submer	6.5	15	5	1	230	1750	1969/2009	4	165	DIP	Massillon	AEP	Portable	L-C-S							
X	2	Lake Cable #2	Jackson	5441 Peninsula Dr,NW		MYR	4RX50M4-21	150	2-Submer	6.5	15	5	1	230	1170	1969/2016	4	241	DIP	Massillon	AEP	Portable	L-C-S							
X	3	Lake Cable #3	Jackson	5812 Island Dr,NW		HYD	C4SXP300EB	180	2-Submer	7.5	23	3	3	230	1750	2020 / 2020	6	310	HDPE	Massillon	AEP	On Site	M-T-M							
X	4	Lake Cable #4	Jackson	5631 North Island Dr,NW		MYR	4RX50M4-21	150	2-Submer	6.5	15	5	1	230	1170	1969/2004	4	269	DIP	Massillon	AEP	Portable	L-C-S							
X	5	Lake Cable #5	Jackson	5419 Island Dr,NW		MYR	4RX50M4-21	150	2-Submer	4615	30	5	1	230	1760	1969/2016	4	165	DIP	Massillon	AEP	Portable	L-C-S							
X	6	Lake Cable #6	Jackson	5783 West Blvd,NW	463	HYD	S4MXP500EB	355	2-Submer	8.5	23	5	3	230	1150	2018 / 2018	6	20	DIP	Massillon	AEP	On Site	M-T-M							
X	7	Lake-O-Springs	Jackson	5681 Spring Lake Rd,NW	92	HYD	HPGFHX300E/FC	96	2-Grinder	7.75	26	3	3	230	1150	2021 / 2021	4	648	CIP	Massillon	AEP	On Site	M-T-M							
X	8	Uniontown	Lake	13313 Cleveland Ave.		MYR	4VHX150M4-43	540	2-Submer	8.625	55	15	3	460	1750	2004 / 2022	8	1600	DIP	Summit via # 37	Ohio Edison	On Site	M-T-M							
X	9	Heritage Glen	Lake	12655 Mogadore Rd. N.W.		MYR	4VCX500m4-43	880	2-Submer	11.75	133	50	3	460	1750	2002	10	5810	dip/pvc	Summit via # 37	Ohio Edison	On Site	M-T-M							
	10	Water Tower	Lake	3152 E. Pine St.																		N/A								
	11	Meter Vault	Lake	11086 Cleveland Ave.																		N/A								
X	12	Lake Center	Lake	3001 Lake Center St.,		HOM	H4HXP1000EC	300	2-Submer	9.25	64.5	10	3	240	1750	1995/ 2016	6	1750	DIP52	Canton	Ohio Edison	On Site	P-R							
X	13	Fairwynde	Lake	2488 Lake Center St.		HYD	S4NX500FC	132	2-Submer	7.25	39	5	3	460	1750	2003/2003	4	1200	PVC-SDR25	Canton	Ohio Edison	On Site	P-R							
X	14	Wellington Woods	Plain	1944 Summerchase Rd,NE	99	HYD	S4NX500CC	135	2-Submer	6.7	32.5	5	1	230	1750	1992/2013	4	1160	PVC-SDR18	Canton	AEP	On Site	P-R							
X	15	Beacon Hill	Lake	2060 Brumbaugh St,NW		HYD	S4TX7500FC	670	2-Submer	13.375	192	75	3	460	1750	1995/2013	8	6245	PVC-SDR21	Canton	Ohio Edison	On Site/MG-100/190	M-T-M							
	16	Hossler	Jackson	4412 Hossler Dr. NW		MYR	WGX50-03		2-Grinder	6		5	3	208	3450	2012	2		PVC	Canton	AEP	Portable	M-T-M							
X	17	Myers Lake	Canton	1602 Whipple Ave,NW	563	HYD	S6LXP750FB	675	2-Submer	10	26	7.5	3	460	1150	2024/2024	10	220	HDPE	Canton	AEP	On Site	M-T-M							
X	18	9th St.	Canton	4001 9th ST NW		MYR	4VHX100M4-43	200	2-Submer	8.00"	55	10	3	460	1750	2007/2014	4	156	PVC	Canton	AEP	On Site	M-T-M							
X	19	Lexington Farms	Plain	1800 Easton NE		HYD	S6LX4000FC	627	2-Submer	10.75"	86	40	3	460	1750	2006 / 2010	10	2804	PVC	Canton	AEP	On Site	P-R							
X	20	Thirteenth St	Perry	4760 13th St,NW		HYD	H4HX1500FC	250	2-Submer	8.75	60	15	3	460	1750	2010/2024	6	623	CIP	Canton	AEP	On Site	M-T-M							
X	21	Sixteenth St	Perry	4632 16th St,NW		MYR	4VX50M4-21	100	2-Submer	6.5	32	5	1	230	1750	2010/2010	4	142	CIP	Canton	AEP	On Site	M-T-M							
X	22	Castlebar	Jackson	4549 Castlebar,NW		HYD	S4LX2500EC	450	2-Submer	9.75	85	20	3	230	1780	1974/2015	4	580	DIP	Massillon	AEP	On Site	P-R							
X	23	Gambrinus	Canton	2415 Harrison St,SW	1298	GRDF	SE1.35.A60	1141	Dry Pit Sub.	11.06	108	30	3	460	1779	1967/ 2022	18	300	CIP	Canton	AEP	On Site	N/A							
	24	North Lawrence	Nrth Lawrence																											
X	25	41st Street	Plain	4101 Regentview Ave,NE		HYD	HPGFHX500EC	85	2-Grinder	9	60	5	3	230	1750	2020/2020	3	440	HDPE	Canton	AEP	Portable	M-T-M							
X	26	Piccadilly	Perry	4759 Piccadilly,SW		HYD	S4KXP2500E/FC	344	2-Suct Lift	9.1563	90	25	3	230	1750	2021/2021	8	1500	CIP	Canton	AEP	Portable	M-T-M							
X	27	Village Green	Lexington	10955 Julie Ave. NE		HYD	S4KXP2000FC	300	2-Submer	10.13	100	20	3	460	1750	2019/2019	8	9700	HDPE	Alliance	Ohio Edison	On Site	M-T-M							
X	28	Electon St.	Washington	2712 Beechwood Ave NE		MYR	4VX50M4-43	200	2-Submer	6.75	26.7	5	3	460	1750	2008/2016	4	2022	PVC	Alliance	Ohio Edison	On Site	M-T-M							
X	29	Beechwood	Washington	3327 Beechwood Ave NE		MYR	4VHX150M4-43	200	2-Submer	8.5	63.8	15	3	460	1750	2008/2008	4	2034	PVC	Alliance	Ohio Edison	On Site	M-T-M							
X	30	Tioga	Perry	4630 Tioga St,NW		HYD	S4HX1500JC	325	2-Submer	9.5	70	15	3	460	1750	2010/2017	8	966	CIP	Massillon	AEP	On Site	M-T-M							
X	31	Metro Circle	Jackson	5656 Dressler Rd,NW	141	HYD	S4NVX500FC	160	2-Submer	6.19	26	5	3	460	1750	2018 / 2018	4	245	HDPE	Canton	AEP	On Site	M-T-M							
X	32	Fairhope	Plain	4619 Lousiville Rd,NE		MYR	8VLX400M6	2000	2-Submer	13.63	45	40	3	460	1150	2016 / 2016	18	4600	PCCP	Canton	AEP	On Site	M-T-M							
X	33	Massillon Detention	Perry	3452 12th St. NW		F/M	D5731MV	7000	3-Submer		200	225	3	460	1750	2008/2008	24		DIP	Massillon	Ohio Edison	On Site	N/A							
	34	Promler	Jackson	6225 Promler N.W.		HYD	SP50	65	2-Submer	n/a	15	0.5	1	240	1750	2000 2008	2	100?	PVC	Canton	AEP	Portable	N/A							
X	35	Fleetwood	Jackson	5400 Fleetwood,NW		HYD	S6LX1000M3-4	800	2-Submer	10.5	28	10	3	240	1150	1979/2014	10	1930	DIP	Massillon	AEP	On Site	P-R							
X	36	Waco	Canton	2727 24th St. S.E		MYR	4VHX75M4-43	275	2-Submer	8.13	53	7.5	3	460	1750	2020	6	3470	HDPE	Canton	AEP	On Site	M-T-M							
X	37	Cleveland Ave	Lake	13870 Cleveland Ave	697	F/M	6-85443	1230	2-FI Suct	10.688	113	50	3	460	1750	1996/1996	12	14860	DIP	Summit County	Ohio Edison	On Site	N/A							
	38	Briardale	Perry	3452 12th St. NW		MYR	WGX50-43-25	150	2-Submer	4.75	35	5	3	460	1750	2007/2007	4	35	PVC	Massillon	Ohio Edison	Portable	M-T-M							
X	39	Foxvale	Marlboro	9467 Foxvale NE	263	HYD	H4HX1000FC	241	2-Submer	8.25	50	10	3	460	1750	2013	6	3524	PVC	Marlboro WWTP	Ohio Edison	On Site	M-T-M							
X	40	Eighteenth St	Jackson	1804 Woodlawn Ave,NW	100	MYR	4RX50M4-43	80	2-Submer	7.25	40	5	3	460	1750	2009 / 2009	4	550	CIP	Canton	AEP	MG-50	M-T-M							
X	41	East Sparta	Pike	2219 Farber St,SE	389	HYD	C4SXP1500FC	320	2-Submer	8.63	72	15	3	460	1750	2024/2024	8	2480	HDPE	Tusc.County	AEP	On Site	M-T-M							
X	42	Bowdale	Jackson	3482 Bowdale Ave,NW		HYD	S4N500JC	120	2-Submer	7.75	50	5	3	230	1750															

Last Updated 1/24/23		STARK COUNTY LIFT STATIONS																																					
Lift Station			Location		Map Book	Pump Description						Motor Description				In Operation		Force Main Description				Power	Generator																
	No.	Name	Township	Street Address		Mfg. *	Model No.	Cap.	No. & Type	Imp.Dia.	TDH	HP	Phase	Voltage	RPM	Station/Pumps	Size	Length	Type	Discharges To	Company	Required																	
X	60	Broadford St.	Sandy	7424 Broadford St,SE	350	HYD	S4L2000M3/4-4	570	2-Submer	9.63	62	20	3	240	1750	1983/2015	8	2422	PVC-SDR26	Magnolia STP	AEP	On Site	P-R																
X	61	Perry Drive SW	Perry	1601 Perry Dr,SW	720	HYD	S6LX750EB	600	2-Submer	10	27	7.5	3	230	1150	1980/2011	10	1800	DIP	Massillon	AEP	On Site	H-O-R																
X	62	Eileen St. SW	Perry	1000 Eileen Ave. SW	144	HYD	S4NX750FC	145	2-Submer	7.25	41	7.5	3	460	1750	2000/2016	4	1510	PVC-SDR21	Massillon	Ohio Edison	On Site	P-R																
X	63	South Park	Canton	3817 12th St,NW		HYD	S4N500JC	160	2-Submer	7.5	43	5	3	230	1750	1986/2017	4	1750	PVC-SDR21	Canton	AEP	Portable	H-O-R																
X	64	Stump Avenue	Perry	3449 Stump Ave,SW		FLT	CP3152	425	2-Submer	#432	75	20	3	460	1750	1988/2013	6	1350	PVC-DR25	Navarre STP	Ohio Edison	On Site	M-T-M																
X	65	Greenford Avenue	Perry	3930 Greenford Ave,SW		MYR	4RX50M4-21-25	125	2-Submer	7.75	42	5	1	230	1750	1988/2006	4	560	PVC-DR25	Navarre STP	Ohio Edison	Portable	M-T-M																
X	66	Magnolia	Sandy	333 Basin St	570	MYR	4VC400M4-43	803	2-Submer	10	79	40	3	460	1750	1988/2020	8	2540	PVC-DR25	Magnolia STP	AEP	On Site	M-T-M																
X	67	Canal Street	Sandy	101 Canal St	255	HYD	S4KX	200	2-Submer	9.55	91.5	20	3	230	1750	2000/2015	4	1307	PVC	Magnolia STP	AEP	On Site	P-R																
X	68	Nottingham	Plain	1918 Hunting Valley,NW		MYR	4RX50M4-2/43	125	2-Submer	7.5	43	5	3	240	1750	1996/2024	6	1000	PVC-SDR25	Canton	AEP	On Site	P-R																
X	69	Peach Glen	Lake	11076 Peach Glen,NW		MYR	4RX50M4-21	228	2-Submer	7.0	38	5	1	230	1750	1999 / 2016	4	736	PVC	Canton	Ohio Edison	On Site	M-T-M																
X	70	Werley	Osnaburg	228 Werley Rd,SW		MYR	4VCX500M4-43	650	2-Submer	11.5	135	50	3	460	1750	1989/2011	10	5725	C900-DR25	Canton	AEP	On Site	M-T-M																
	70D	Werley Detention Basin	Osnaburg	229 Werley Rd,SW		HYD	S12LX3000FC	2500	2-Submer	13.56	29	30	3	460	870	2000 / 2000				Canton	AEP	On Site	M-T-M																
X	71	Trump Road	Canton	304 Trump Rd,SE		HYD	S4L2500M4-4	850	2-Submer	10.38	70	25	3	460	1750	1989/2021	10	3200	PVC-DR25	Canton	AEP	On Site	P-R																
	72	East Canton	Osnaburg	428 Church St,W		HYD	SK75M2		2-Submer	n/a		0.75	1	230	1750	??/2001	2	343	DIP	Canton	AEP	Portable	N/A																
X	73	Nobles Pond P1&P2	Jackson	5148 Wales Ave,NW		HYD	S6LXP4000FC	1433	2-Submer	10.88	67	40	3	460	1750	2021/2021	14	5500	DIP-CL52	Massillon	Ohio Edison	On Site	M-T-M																
X	73	Nobles Pond P3	Jackson	5148 Wales Ave,NW		HYD	S4LXP4000FC	689	2-Submer	11.13	115	40	3	460	1750	2021/2021	8	5854	DIP	Massillon	Ohio Edison	On Site	M-T-M																
X	74	Gloucester	Jackson	4388 Sparrow Ridge Ave,NW		HYD	S4NX500CC	110	2-Submer	6.9	35	5	1	230	1750	1990/2017	4	690	PVC-DR21	Massillon	Ohio Edison	On Site	H-O-R																
X	75	15th & Miles	Perry	Corner of 15th and Miles Ave		HYD	S4N300M2-4	210	2-Submer	6.5	30	3	1	230	1750	1974/2018	4	115	CIP	Massillon	AEP	Portable	N/A																
X	76	Sandy Creek	Sandy	8941 James St SE	320	HYD	S4LX2500EC	600	2-Submer	10.5	78	25	3	460	1750	2011/ 2011	8	10620	PVC-DR18	Magnolia STP	AEP	On Site	P-R																
X	77	Radio Tower	Canton	515 25th St. N.W.																	AEP	On Site	N/A																
X	78	Bruening Circle	Canton	3275 Bruening Cir,SW		MYR	4VH75M4-03	150	2-Submer	8.25	66	7.5	3	208	1750	1998/2016	6	1403	PVC-	Canton	AEP	On Site	P-R																
X	79	Cheyenne St.	Canton	4814 Cheyenne St,SE		HYD	S6LX3000FC	1105	2-Submer	10.5	66	30	3	460	1750	1999/	12	7206	DIP	Canton	AEP	On Site	P-R																
X	80	Tulane	Nimishillen	3717 Tulane Ave,NE		HYD	H4H1500M4-4	950	2-Submer	9.5"	30	15	3	460	1150	19??/2023	8	10351	DIP	Canton	AEP	Portable	M-T-M																
X	81	Plum St.	Nimishillen	6038 Plum St,NE		MYR	4RC150M4	185	2-Submer	9.41	88	15	3	460	1728	19??/2015	6	2436	DIP	Canton	AEP	Portable	M-T-M																
X	82	Westmore	Nimishillen	4875 California St,NE		MYR	4VH100M4-43-35	200	2-Submer	8.88	69	10	3	460	1750	??/2018	6	4538	DIP	Canton	AEP	On Site	M-T-M																
X	83	Limaville	Lexington	115 Atwater St. S.E.		MYR	4VCX300M4-43	265	2-Submer	10"	98	30	3	460	1750	2018	8	17612	HDPE	Alliance	Ohio Edison	On Site	M-T-M																
X	84	Pilot View	Nimishillen	6262 Pilot Knob Ave,NE		EB	80DLFU63.74	236	2-Submer		32	5	3	460	1728	??/2011	6	928	DIP	Canton	AEP	Portable	M-T-M																
X	85	Pilot Knob	Nimishillen	6790 Pilot Knob Ave,NE		HYD	HVS200M2-2-35	20	2- Grinder	5.313		2	1	230	3450	??/2020	4	20	DIP	Canton	AEP	Portable	M-T-M																
X	86	Easton	Nimishillen	5511 Easton St,NE		MYR	4VEX250M4-43-30	300	2-Submer	10.5	119	25	3	460	1750	/2011	6	4920	DIP	Canton	AEP	On Site	M-T-M																
X	87	Winchester LS	Plain	3695 Boettler NE	210	MYR	4VX75M4-23	190	2-Submer	7.5	46	7.5	3	230	2001	2001/2001	6	3100	PVC	Canton	AEP	On Site	M-T-M																
X	88	Berkshire Farms	Jackson	7200 Lutz N.W.		MYR	4VHX100M4-03	155	2-Submer	8.75	75	10	3	208	1750	2017	4	1500	PVC	Massillon	Ohio Edison	On Site	M-T-M																
	102	Skyland Hills STP	Paris	14000 Lincoln St. SE	207								3	230							AEP	Portable																	
X	103	DeeMar STP	Bethlehem	5242 Emil St,SW		HYD	4RX30M4-23	200	2-Submer	5.68	20	3	3	230	1750	1971/ 2022	4	20	Steel	Dee Mar	AEP	Portable	M-T-M																
	105	Marlboro	Marlboro	12997 Marlboro Ave. NE	152								3	460							Ohio Edison	On Site																	
X	107	Magnolia STP	Sandy	10156 Bowmont Ave. SE									3	460							AEP	MG-100																	
X	108	Molly Stark STP	Nimishillen	7620 Columbus Rd NE									3	230							AEP																		
X	113	Springvalley STP	Lawrence	8565 Cherryridge,NW	321	HYD	S4NX500JC	277	2-Submer	6.9"	25	5	3	230	1750	1980/2001				Springvalley STP	Ohio Edison	On Site	M-T-M																
		</																																					